

PUBLIC PRIVATE SCHOOL

STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC PRIVATE SCHOOL INSPECTION REPORT

Seocoded 25.809612/-80.224941

PURPOSE: REINSPECTION
 ROUTINE CHANGE OF OWNER
 CONSTRUCT. CONSULTATION
 COMPLAINT EPIDEMIOLOGY
 QA SURVEY PREOPENING
 OTHER

TYPE: Public School

CENSUS	FEMALES	MALES
1357	679	678



NAME Miami Jackson High School
ADDRESS 1751 NW 36 Street **CITY** Miami
OWNER M-DCSB Food and Nutrition **ZIP** 33142
PERSON IN CHARGE Dr. Burth **PHONE** (305) 634-2621
E-MAIL burthe@dadeschools.net

RESULTS:
 Satisfactory
 Incomplete
 Unsatisfactory
OUT OF BUSINESS
Correct Violations by
 Next Inspection
 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
08:00	08:45	05/15/2013	32763	13-51-08160

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance" for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

SCHOOL SANITATION

- 1. School Site
- 2. Playground Equipment
- 3. Athletic Equipment

- 8. Natural Ventilation
 - 9. Mechanical Ventilation
- SANITARY FACILITIES**

- 15. Handwash Facilities
- 16. Showers/Fixtures
- 17. Shower Water Temp.

- LIQUID/SOLID WASTE**
- 21. Sewage Disposal
 - 22. Solid Waste

- SAFETY**
- 26. First Aid Kit

BUILDINGS

- 4. Construction
- 5. Maintenance & Repair
- 6. Lighting/Foot-Candles
- 7. Heating, Ventilation, A/C

- 10. Provided/Accessible
- 11. Cleanliness & Repair
- 12. Toilet Facilities
- 13. Separation of Sexes
- 14. Fixture Ratio

- WATER SUPPLY**
- 18. Installed/Operated/Maintained
 - 19. Drinking Fountains
 - 20. Approved Source

- VECTOR/VERMIN CONTROL**
- 23. Infestation/Control
 - 24. Brush/Trash
 - 25. Water Collection/Drainage

- FOOD**
- 27. Food Insp. Rpt.
- OTHER**
- 28.
 - 29.

COMMENTS AND INSTRUCTIONS

Violation #5 Clean dusty air vents and air returns throughout bld. 4. Secure cables to floor in Rm. 403 and 404 in bld. 4. Replace discolored ceiling tiles in Rm. 402 in bld. 4. Repair clogged floor drain outside walk-in refrigerator and cover hole on wall inside storage room outside walk-in refrigerator in Rm. 051 in bld. 3. Work order in place.
 Code Reference FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

Violation #6 Replace burnt out light bulbs in Rm. 404 in bld. 4 and Rm. 051 in bld. 3. Work order in place.
 Code Reference FAC: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any

Continued On Page 2

INSPECTION CONDUCTED BY: Cynthia Campos PHONE: (305) 623-3500
 INSPECTION COND SIGNATURE: [Signature] PHONE: _____
 COPY OF REPORT RECEIVED BY: [Signature] DATE: 5/15/2013

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY PUBLIC HEALTH UNIT
Public/Private School



Name: Miami Jackson High School

Date: 05/15/2013

Identification No: 13-51-08160

Comments and Instructions (Continued from Page 1):

occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Note: Inspection done late per school board request.

Copy of Report
Received By:

A handwritten signature in black ink, appearing to be "Dr. S".

Inspector Cynthia Campos

Page 2